


### UPVC Schedule 40 Clear Pipe 3m Length

#### Standards

- Manufactured to ASTM D1785: Standard Specification for Polyvinyl Chloride (PVC) plastic pipe, Schedule 40
- Approved by NSF International for use with potable water (NSF Std 61: Drinking Water System Components - Health Effects)



#### Dimensions

DN	NB	Av OD	OD Tolerance	Min Wall Thickness	Part No
15mm	½"	21.34	+/- 0.10	2.76	4004-005
20mm	¾"	26.67	+/- 0.10	2.87	4004-007
25mm	1"	33.40	+/- 0.12	3.37	4004-010
40mm	1 ½"	48.26	+/- 0.15	3.68	4004-015
50mm	2"	60.32	+/- 0.15	3.91	4004-020
80mm	3"	88.90	+/- 0.20	5.48	4004-030
100mm	4"	114.30	+/- 0.22	6.01	4004-040
155mm	6"	168.28	+/- 0.27	7.11	4004-060
195mm	8"	219.08	+/- 0.38	8.17	4004-080