



## Equipment Service Scope of Works & Spare Parts

| <b>V10K Automatic Chlorinator</b>               | <b>Major Service Yearly (mandatory)</b> | <b>Minor Service Twice Yearly (recommended)</b> |
|---|---|---|
| ▪ Isolate Chlorinator From Service              | ✓                                       | ✓   |
| ▪ Strip & Clean Chlorinator (note any defects)  | ✓                                       |   |
| ▪ Remove & Clean Rotameter Tube                 | ✓                                       | ✓   |
| ▪ Record Rotameter Tube Size                    | ✓                                       | ✓   |
| ▪ Overhaul Chlorinator With Manufacturer PM Kit | ✓                                       |   |
| ▪ Reassemble & Install Back Into Service        | ✓                                       | ✓   |
| ▪ Vacuum & Operation Test                       | ✓                                       | ✓   |

**Major Service Parts:**  
Maintenance Kit

**Minor Service Parts:**

### **WESTERN AUSTRALIA**

9 Chifley Brace  
Jandakot WA 6164  
**Telephone: (08) 9412 6100**  
**Fax: (08) 9412 6199**  
Email: [hydramet@hydramet.com.au](mailto:hydramet@hydramet.com.au)

### **SOUTH AUSTRALIA**

29 Deloraine Road  
Edwardstown SA 5039  
**Telephone: (08) 8374 7800**  
**Fax: (08) 8374 7899**  
Email: [hydrasa@hydramet.com.au](mailto:hydrasa@hydramet.com.au)

### **VICTORIA**

Unit 4, 47-51 Little Boundary Road  
Laverton North VIC 3026  
**Telephone: (03) 9325 3900**  
**Fax: (03) 9318 9653**  
Email: [hydravic@hydramet.com.au](mailto:hydravic@hydramet.com.au)