



Equipment Service Scope of Works & Spare Parts

S10K Automatic Chlorinator	Major Service Yearly (mandatory)	Minor Service Twice Yearly (recommended)
▪ Isolate Chlorinator From Service	✓	✓
▪ Strip, Clean & Inspect Chlorinator (note any defects)	✓	
▪ Remove & Clean Rotameter Tube	✓	✓
▪ Record Rotameter Tube Size	✓	✓
▪ Overhaul Chlorinator With Manufacturer PM Kit	✓	
▪ Reassemble & Install Back Into Service	✓	✓
▪ Vacuum & Operation Test	✓	✓

Major Service Parts:
Maintenance Kit

Minor Service Parts:

WESTERN AUSTRALIA

9 Chifley Brace
Jandakot WA 6164
Telephone: (08) 9412 6100
Fax: (08) 9412 6199
Email: hydramet@hydramet.com.au

SOUTH AUSTRALIA

29 Deloraine Road
Edwardstown SA 5039
Telephone: (08) 8374 7800
Fax: (08) 8374 7899
Email: hydrasa@hydramet.com.au

VICTORIA

Unit 4, 47-51 Little Boundary Road
Laverton North VIC 3026
Telephone: (03) 9325 3900
Fax: (03) 9318 9653
Email: hydravic@hydramet.com.au