



## Equipment Service Scope of Works & Spare Parts

<b>ATI Chlorine Leak Detection System with Auto Test</b>	<b>Major Service Yearly (mandatory)</b>	<b>Minor Service Twice Yearly (recommended)</b>
▪ Test Functions & Alarms (note any defects)	✓	✓
▪ Replace Back-Up Battery	✓	
▪ Replace Chlorine Sensor	✓	
▪ Calibrate Chlorine Sensor & Test Auto Test Operation	✓	✓
▪ Gas Generator	✓	
▪ Fill Out Calibration Sheet	✓	✓
▪ Record Serial Number	✓	

### Major Service Parts:

Battery Back-Up Cell, Chlorine Sensor, Gas Generator

### Minor Service Parts:

Sensor Calibration

Weekly testing is mandatory as per AS2927

### **WESTERN AUSTRALIA**

9 Chifley Brace  
Jandakot WA 6164

**Telephone: (08) 9412 6100**

**Fax: (08) 9412 6199**

Email: [hydramet@hydramet.com.au](mailto:hydramet@hydramet.com.au)

### **SOUTH AUSTRALIA**

29 Deloraine Road  
Edwardstown SA 5039

**Telephone: (08) 8374 7800**

**Fax: (08) 8374 7899**

Email: [hydrasa@hydramet.com.au](mailto:hydrasa@hydramet.com.au)

### **VICTORIA**

Unit 4, 47-51 Little Boundary Road  
Laverton North VIC 3026

**Telephone: (03) 9325 3900**

**Fax: (03) 9318 9653**

Email: [hydravic@hydramet.com.au](mailto:hydravic@hydramet.com.au)